



Environmental Health & Safety
District Water Quality Sampling

TESTING METHODS

Sample Type: First Draw

Testing Method: EPA 200.8

Samples were collected in general accordance with the EPA’s Lead in Drinking Water in Schools and Non-Residential Buildings, and Lead & Copper Rule Standards. All samples were analyzed at laboratories accredited by the Oregon Environmental Laboratory Accreditation Program (ORELAP) for testing under the Safe Drinking Water Act

Sylvania Child Development Center

| Building | Level | Location | Source Type | Sample Date | Lead Result (ppb) |
|----------|-------|---------------------------------|----------------------|-------------|-------------------|
| Main | 1 | Room 106 Lactation | Sink | 6/18/24 | 0.675 |
| Main | 1 | Room 107 | Sink | 6/18/24 | 0.242 |
| Main | 1 | Room 108 | Sink (Right) | 6/18/24 | 1.110 |
| Main | 1 | Room 108 | Sink (Left) | 6/18/24 | 0.644 |
| Main | 1 | Room 110 | Sink | 6/18/24 | ND |
| Main | 1 | Restroom (Right) | Sink | 6/18/24 | ND |
| Main | 1 | Restroom (Left) | Sink | 6/18/24 | ND |
| Main | 1 | Near Room 116 | Bottle Fill Station | 6/18/24 | ND |
| Main | 1 | Laundry Room | Sink | 6/18/24 | 0.233 |
| Main | 1 | Room 115 Kitchen | Sink (Right) | 6/18/24 | ND |
| Main | 1 | Room 115 Kitchen | Sink (Left) | 6/18/24 | ND |
| Main | 2 | Break Area | Sink | 6/18/24 | 0.200 |
| Main | 2 | Gender Neutral Restroom (Left) | Sink | 6/18/24 | 0.336 |
| Main | 2 | Gender Neutral Restroom (Right) | Sink | 6/18/24 | ND |
| Bldg 2 | 1 | Room 117 | Sink (Tall) | 6/18/24 | 0.613 |
| Bldg 2 | 1 | Room 117 | Sink (Short) | 6/18/24 | 0.668 |
| Bldg 2 | 1 | Room 118 | Sink | 6/18/24 | 2.970 |
| Bldg 2 | 1 | Room 119 | Sink – Northeast | 6/18/24 | 0.305 |
| Bldg 2 | 1 | Room 119 | Sink – Southeast | 6/18/24 | 0.847 |
| Bldg 2 | 1 | Room 119 | Sink – Southwest | 6/18/24 | 0.427 |
| Bldg 2 | 1 | Room 119 | Sink – Northwest | 6/18/24 | 1.220 |
| Bldg 2 | 1 | Room 120 | Sink (Tall) | 6/18/24 | 0.245 |
| Bldg 2 | 1 | Room 120 | Sink (Short) | 6/18/24 | 1.270 |
| Bldg 3 | 1 | Room 121 | Sink (Tall) | 6/18/24 | 0.977 |
| Bldg 3 | 1 | Room 121 | Sink (Short) | 6/18/24 | 1.390 |
| Bldg 3 | 1 | Room 122a | Sink (Tall - South) | 6/18/24 | ND |
| Bldg 3 | 1 | Room 122a | Sink (Short - South) | 6/18/24 | 0.537 |
| Bldg 3 | 1 | Room 122b | Sink (Tall - North) | 6/18/24 | ND |
| Bldg 3 | 1 | Room 122b | Sink (Short - North) | 6/18/24 | 0.401 |
| Bldg 3 | 1 | Room 124 | Sink (Tall) | 6/18/24 | 1.370 |
| Bldg 3 | 1 | Room 124 | Sink (Short) | 6/18/24 | 1.340 |

Sampling methodology and the interpretation of laboratory results were based on the EPA guidance document entitled; *3Ts for Reducing Lead in Drinking Water in Schools.*

First draw samples were collected following the Test Method: EPA 200 procedure.

Laboratory analysis indicates that all water samples collected contained lead at concentrations that were below the EPA action level of 15 ppb.

ppb = parts per billion (i.e., 15 ppb = 0.015 mg/L)